



## Walnut Creek Special Utility District

P.O. Box 657  
1155 Hwy. 199 West  
Springtown, Texas 76082  
(817) 220-7707  
(817) 523-4463  
Fax (817) 523-0359

November 4, 2020

### Mandatory Language for a Maximum Contaminant Level Violation MCL, LRAA/ TTHM

The Texas Commission on Environmental Quality (TCEQ) has notified the Walnut Creek SUD TX1840008 public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on a locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in **quarter three 2020 of 0.081 mg/L for DBP2-03.**

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

The corrective actions taken after quarter 1 2020 have resolved the problem. However, since this is based on locational running annual average (LRAA), it may take at least one more quarter for the average to fall below notification levels.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact **Walnut Creek Special Utility District at 817-220-7707.**

Posted /Delivered on November 4, 2020